

February 24, 2005

VISTA RESEARCH GROUP, LLC
JIM CHANDLER
1554 TOWNSHIP ROAD 805
PO BOX 321
ASHLAND OH 44805

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: VISTA RESEARCH GROUP, LLC
Product Name: VISTACLEAR DENTAL WATERLINE TREATMENT SYSTEM
Model Number(s): 1000, 1000-23-C, 1000-34-C, 1000-46-C and 1000-47-C
Product File No: 20040408

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.41(3)(a) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2010.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product is approved as acceptable form of backflow protection of the water supply serving dental units.
- The backflow protection devices in this product must be tested at least once per year. The testing must be done in accordance with the manufacturer's testing requirements as noted in their "Annual Backflow Preventer Valve Testing" procedures. Copy of the test results should be recorded and kept at the installation site. Any repairs or replacement of the backflow preventers should be noted on test report.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov